

Certificate

No. **ESY 086470 0296 Rev. 00**

Holder of Certificate: **Ginlong Technologies Co., Ltd.**

No.57 Jintong Road
Binhai Industrial Park, Xiangshan
315712 Ningbo, Zhejiang
PEOPLE'S REPUBLIC OF CHINA

Product: **Converter**
Hybrid Inverter

Model(s): **S6-EH1P3K-L-PLUS, S6-EH1P3.6K-L-PLUS,
S6-EH1P4.6K-L-PLUS, S6-EH1P5K-L-PLUS,
S6-EH1P6K-L-PLUS, S6-EH1P8K-L-PLUS,
S6-EH1P3K-L-PLUS(21A), S6-EH1P3.6K-L-PLUS(21A),
S6-EH1P4.6K-L-PLUS(21A), S6-EH1P5K-L-PLUS(21A),
S6-EH1P6K-L-PLUS(21A), S6-EH1P8K-L-PLUS(21A)**

Parameters: See next pages.

Applicable standards: EN 50549-1:2019
EN 50549-10:2022
RfG:2016
NC RfG:2018
PTPIREE:2021

This Certificate confirms the compliance with the above listed standards on a voluntary basis. It refers only to the sample submitted to TÜV SÜD Product Service GmbH and does not certify the quality or safety of the serial products. It was issued according to TÜV SÜD Product Service certification program Photovoltaics and Grid Integration. For details see: www.tuvsud.com/ps-cert

Test report no.: 7040925142158-00

Date, 2026-02-24

(Kai Zhao)

Certificate

No. ESY 086470 0296 Rev. 00

Technical Certifier (Kai Zhao) appointed by Certification Body TÜV SÜD Product Service GmbH performed assessment of the products listed in this certification in the place: Ridlerstraße 65, 80339 Munich, Germany.

Test requirement	<p>The certification complies with the requirements of the following documents for PPM installations of Type A</p> <p>EN 50549-1:2019 Requirements for generating plants to be connected in parallel with distribution networks - Part 1: Connection to a LV distribution network - Generating plants up to and including Type B</p> <p>EN 50549-10:2022 Requirements for generating plants to be connected in parallel with distribution networks – Part 10: Tests for conformity assessment of generating units</p> <p>RfG:2016 Commission Regulation (EU) 2016/631 of 14 April 2016 establishing a network code on requirements for the connection of generating units to the Network (OJ EU L 112/1 of 27.4.2016)</p> <p>NC RfG:2018 General applicability requirements resulting under EU commission regulation 2016/631 of 14 April 2016 establishing a network code on requirements for the connection of generating units to the grid (NC RfG-2018) - approved by the Decision of the President of the Energy Regulatory Office DRE.WOSE.7128.550.2.2018.ZJ dated 2 January 2019.</p> <p>PTPiREE:2021 Conditions and procedures for the use of certificates in the process of connecting modules generation modules to the power grid V1.2</p>
Designation and type of certification programme	1(a) according to EN ISO/IEC 17067 Based on Photovoltaics and Grid Integration Certification Program (Revision 7, Dated 30 Aug 2022) for Poland Grid Code
Manufacturer & Address	Ginlong Technologies Co., Ltd. No.57 Jintong Road, Binhai Industrial Park, Xiangshan, 315712 Ningbo, Zhejiang, PEOPLE'S REPUBLIC OF CHINA
Software version	A2
Expiry date of certificate	2031-01-13

Certificate

No. ESY 086470 0296 Rev. 00

Parameters:

Model	S6-EH1P3K-L-PLUS	S6-EH1P3.6K-L-PLUS	S6-EH1P4.6K-L-PLUS
PV input ratings			
Max. input voltage [V _{DC}]	500		
MPPT voltage range [V _{DC}]	90, ..., 435		
Max. input current [A _{DC}]	16/16	16/16	16/16
Isc PV (absolute maximum) [A _{DC}]	20/20	20/20	20/20
Battery Input / Output			
Battery Type	Li-ion/Lead-acid		
Battery Voltage range [V _{DC}]	40, ..., 60		
Max. Charge / discharge current [A _{DC}]	70/70	80/80	105/105
AC output ratings			
Nominal voltage [V _{AC}]	1/N/PE, 230		
Nominal frequency [Hz]	50		
Max. / Nominal apparent output power [VA]	3000	3600	4600
Max. / Nominal output current [A _{AC}]	13.1	15.7	20
Power factor range	0.8 (leading), ..., 1, ..., 0.8 (lagging)		

Model	S6-EH1P5K-L-PLUS	S6-EH1P6K-L-PLUS	S6-EH1P8K-L-PLUS
PV input ratings			
Max. input voltage [V _{DC}]	500		
MPPT voltage range [V _{DC}]	90, ..., 435		
Max. input current [A _{DC}]	16/16	16/16	32/32
Isc PV (absolute maximum) [A _{DC}]	20/20	20/20	40/40
Battery Input / Output			
Battery Type	Li-ion/Lead-acid		
Battery Voltage range [V _{DC}]	40, ..., 60		
Max. Charge / discharge current [A _{DC}]	112/112	135/135	190/190
AC output ratings			
Nominal voltage [V _{AC}]	1/N/PE, 230		
Nominal frequency [Hz]	50		
Max. / Nominal apparent output power [VA]	5000	6000	8000
Max. / Nominal output current [A _{AC}]	21.8	26.1	34.8
Power factor range	0.8 (leading), ..., 1, ..., 0.8 (lagging)		

Certificate

No. ESY 086470 0296 Rev. 00

Model	S6-EH1P3K-L-PLUS(21A)	S6-EH1P3.6K-L-PLUS(21A)	S6-EH1P4.6K-L-PLUS(21A)
PV input ratings			
Max. input voltage [V _{DC}]	500		
MPPT voltage range [V _{DC}]	90, ..., 435		
Max. input current [A _{DC}]	21/21	21/21	21/21
Isc PV (absolute maximum) [A _{DC}]	24/24	24/24	24/24
Battery Input / Output			
Battery Type	Li-ion/Lead-acid		
Battery Voltage range [V _{DC}]	40, ..., 60		
Max. Charge / discharge current [A _{DC}]	70/70	80/80	105/105
AC output ratings			
Nominal voltage [V _{AC}]	1/N/PE, 230		
Nominal frequency [Hz]	50		
Max. / Nominal apparent output power [VA]	3000	3600	4600
Max. / Nominal output current [A _{AC}]	13.1	15.7	20
Power factor range	0.8 (leading), ..., 1, ..., 0.8 (lagging)		

Model	S6-EH1P5K-L-PLUS(21A)	S6-EH1P6K-L-PLUS(21A)	S6-EH1P8K-L-PLUS(21A)
PV input ratings			
Max. input voltage [V _{DC}]	500		
MPPT voltage range [V _{DC}]	90, ..., 435		
Max. input current [A _{DC}]	21/21	21/21	42/42
Isc PV (absolute maximum) [A _{DC}]	24/24	24/24	48/48
Battery Input / Output			
Battery Type	Li-ion/Lead-acid		
Battery Voltage range [V _{DC}]	40, ..., 60		
Max. Charge / discharge current [A _{DC}]	112/112	135/135	190/190
AC output ratings			
Nominal voltage [V _{AC}]	1/N/PE, 230		
Nominal frequency [Hz]	50		
Max. / Nominal apparent output power [VA]	5000	6000	8000
Max. / Nominal output current [A _{AC}]	21.8	26.1	34.8
Power factor range	0.8 (leading), ..., 1, ..., 0.8 (lagging)		

Certificate

No. ESY 086470 0296 Rev. 00

Scope and function assessment based on the rules for the application of equipment certificates for Power Park Modules (PPMs), as specified in the PTPIREE document.

Parameter	RfG: 2016	NC RfG: 2018	Type A	Type B	Type C	Type D	Result
Frequency range	13.1 (a)	13.1 (a) (i)	Y	N/A	N/A	N/A	Pass
Rate of change of frequency withstand capability (RoCoF) df/dt	13.1 (b)	13.1 (b)	Y	N/A	N/A	N/A	Pass
Power generation module operation mode in which the generated active power decreases in response to an increase in the system frequency above a specified value (LFSM-O)	13.2 (*)	13.2 (a), (b), (f)	Y	N/A	N/A	N/A	Pass
Admissible active power reduction with decreasing frequency	13.3, 13.4 & 13.5	13.4	Y	N/A	N/A	N/A	Pass
Remote ceasing active power	13.6	13.6	Y	N/A	N/A	N/A	Pass
Automatic connection to the network	13.7 & 14.4	13.7 & 14.4 (a)	Y	N/A	N/A	N/A	Pass
Remote control of active power	14.2 (a) (b)	14.2 (b)	N/A	N/A	N/A	N/A	N/A
Ability to withstand voltage dips for connections below 110 kV	14.3	14.3 (a) (i), (b)	N/A	N/A	N/A	N/A	N/A
Automatic power adjustment & manual power adjustment	15.2 (a) (b)	15.2 (a) (b)	N/A	N/A	N/A	N/A	N/A
Power generation module operation mode in which the generated active power increases as a result of the system frequency falling below a specified value (LFSM-U)	15.2 (c)	15.2 (c) (i)	N/A	N/A	N/A	N/A	N/A
Static parameters of the FSM mode	15.2 (d) (i)	15.2 (d) (i)	N/A	N/A	N/A	N/A	N/A
Voltage conditions	16.2 (a)	16.2 (a) (i)	N/A	N/A	N/A	N/A	N/A
Ability to withstand voltage dips for connections above 110 kV	16.3	16.3 (a) (i), (c)	N/A	N/A	N/A	N/A	N/A
Maintaining voltage through reactive power - Capabilities	20.2 (a) & 21.3 (a), (b), (c), (d)	20.2 (a) & 21.3 (b) (i), (c) (i) (iv), (d) (iv) (vi)	N/A	N/A	N/A	N/A	N/A
Fast fault current contribution, symmetrical and asymmetrical faults	20.2 (b), (c) 21.3 (e)	20.2 (b), (c) 21.3 (e)	N/A	N/A	N/A	N/A	N/A
Recovery of active power after short circuit	20.3	20.3 (a)	N/A	N/A	N/A	N/A	N/A

(*) Article 13.2.(b) only applies to Type A PPMs in accordance with RfG:2016.